



# Lead and Copper - 90<sup>th</sup> PERCENTILE COMPLIANCE Report

(For Systems Required to Collect More Than 5 Samples)

**I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.**

PWS ID #: 3165000

City / Town: MALDEN

PWS Name: Malden Water Department

PWS Class: COM  NTNC

**Sampling Frequency:**

(choose one)

- FIRST SEMI-ANNUAL SAMPLING PERIOD
- SECOND SEMI-ANNUAL SAMPLING PERIOD
- REDUCED - ANNUAL

- REDUCED - EVERY THREE YEARS
- LEAD SERVICE LINE (LSL) REPLACEMENT PROGRAM
- DEMONSTRATION

**Step 1:** Place lead results in ascending order (from lowest to highest value) with lowest value at # 1, in the table below. Repeat for copper results. Please report results that are ND or less than (<) the laboratory's reported detection limit (MDL) as zero. Results at or above the laboratory's detection limit (MDL) but below 0.005 mg/L for lead or 0.05 mg/L for copper shall be reported as measured or may be reported as 0.0025 mg/L for lead or 0.025 mg/L for copper.

**Step 2:** Multiply the total number of samples collected by 0.9 (this is your 90<sup>th</sup> percentile sample number). Round to the nearest whole number, if necessary.

**Step 3:** Compare the sample result at the 90th percentile sample number against the corresponding action level. If the 90th percentile value is higher than the action level, then you have an exceedance and are required to contact MassDEP as soon as possible for information on compliance actions. Note: Do not include school results on this form unless the PWS is a school.

No	LEAD RESULTS	COPPER RESULTS
	(ppb)	(ppb)
	Pb	Cu
1	0.10	9.9
2	0.44	16.5
3	0.47	26.5
4	0.62	32.1
5	2.04	41.3
6	2.87	47.1
7	3.63	63.6
8	4.27	72.7
9	7.49	82.0
10	7.51	90.5
11	7.71	92.4
12	8.56	104.0
13	13.30	108.0
14	20.60	113.0
15	21.60	144.0

1 is Lowest Value

My system was required to collect: 15 lead and copper samples. My system collected: 15 lead and copper samples.

Total # of samples collected: 15 x 0.9 = 14 This number is my system's 90<sup>th</sup> percentile sample #.

Circle the 90<sup>th</sup> percentile sample # for both lead and copper in the table above, and enter the results in the appropriate spaces below.

**20.6**  
(Lead result at 90<sup>th</sup> percentile sample#)

Compared to **15 ppb**  
(The lead action level)

**113**  
(Copper result at 90<sup>th</sup> percentile sample#)

Compared to **1300 ppb**  
(The copper action level)



# Lead and Copper - 90<sup>th</sup> PERCENTILE COMPLIANCE Report

(For Systems Required to Collect More Than 5 Samples)

## II. CERTIFICATION:

Check and complete the correct statement for lead as determined by the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

- My system was **at or below** the lead action level.
- My system **exceeded** the lead action level and **2** sampling sites **exceeded** the lead action level.  
(Insert # of samples)

Check and complete the correct statement for copper as determined from the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

- My system was **at or below** the copper action level.
- My system **exceeded** the copper action level and \_\_\_\_\_ sampling sites **exceeded** the copper action level.  
(Insert # of samples)

*My signature below indicates that all sampling sites on this report have been previously approved in writing by the DEP, and both the sites and sampling procedures used comply with 310 CMR 22.06B(7). I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.*

Director, Planning and Sustainability  
Title

Signature of PWS or Owner's Representative

November 2, 2021  
Date



Massachusetts Department of Environmental Protection - Drinking Water  
Program

LCR-D

**Lead and Copper - 90<sup>th</sup> PERCENTILE COMPLIANCE Report**  
(For Systems Required to Collect More Than 5 Samples)

*Please submit Form LCR-C along with this form.*

Rev. 02 - 2019

Page

2

of

2